

# Submittal for approval of materials

dar Pte Al-Hamdash

22 FEB 2020

RECEIVED



Date: 22-02-20

Request no: HAC/MAT/AAR/408 Rev.00

Project no. & title: E16104-0400S/T-02/Ministerial Buildings on Plots 5A & 6A

Employer: <b>ACU</b> ADMINISTRATIVE CAPITAL مركز الاستثمار الإداري العاصمة الإدارية الجديدة	Engineer: <b>dar</b>	Contractor: <b>HASSAN ALLAM</b> CONSTRUCTION
---	-------------------------	--

## 1. Material description (one item only on this form) :

### C15-Perforated Gypsum tiles (60\*60) (ONE SAMPLE)

Area of application : ceiling gypsum tiles

Drawing ref. : N/A

B.O.Q. ref. no.: 9516

Specification Ref. : 9516

Standards: as per attached

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

Attached : 1 Pages A4

## 2. Manufacturer / supplier

Company Name : BECO-MCH

Address : 6 MIT GHAMR ST-SAFIR SQUARE - HELIOPOLIS - CAIRO

Local agent : EDIMEX

## 3. Delivery :

Stock

Country of origin : EGYPT

Availability

☒ Locally Manufactured

☐ Overseas

Delivery : Ex-works/ total duration

Estimated time of arrival on site

Program :

Date material required on site

Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : Eng. Mostafa Shalaby

Signature: *[Signature]*

## 4. Engineer's Representative comments:

*only for files 12.5 and 13.5*  
*\* Submitted acoustic test is noted*  
*However, Complete third party*  
*test reports complying with*  
*specs requirements to be provided*  
*\* Subject to approved sample with*  
*thick perforation size, color*  
*site marking and test approval*  
*of main and secondary running*  
*As per Approved Hanging system*

Signature: *A-Ra*

Date: 29/2/20

☐ Approved

☒ Approved as noted

☐ Revise and

resubmit

☐ Rejected

☐ Sample required

☐ Tests required

☐ Additional

information

☐ required

☐ Manufacturer's

guarantee

☐ required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

dar