

# Submittal for approval of materials

Date: 5-Jul-2020

Request no: MAR-Arch-0318 Rev - 00

Project no. & title: E18029-0100M - Four Seasons Hotel Expansion & Golf Resort at Sharm El Sheikh - Egypt

Package title: Suspension System - Alternative

Employer:  Egyptian Company for Development & Real Estate Projects	Project Management Consultant:  DAR Al-Handasah Consultants (Shair & Partners)	Supervision Consultant:  SCG - Shaker Consultancy Group	Contractor:  ATRIUM Quality Contractors
---	--	--	---

## 1. Material description (one item only on this form) :

Metal Galvanized Suspension System - Special Thickness 0.8 mm

Attachments: 29 A4 + Catalog  
Sample Board

Area of application: Public Area

Drawing ref. :

B.O.Q. ref. no.:

Specification Ref. :

9260

Standards:

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

## 2. Manufacturer / supplier

BEECO

Company Name :

Omega

Address :

Local agent :

## 3. Delivery :

Country of origin : Europe

Availability

☒ Locally Manufactured

☐ Overseas

Delivery :

Ex-works/ total duration

Estimated time of arrival on site

Program :

Date material required on site

Latest date for order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same time E18029-0100M Time:

Submitted by: Hamdy Salem

Signature:

Project Director

## 4. Supervision Consultant's Representative comments:

The Specified Thickness for Galvanized  
Suspension System is 0.8 mm for  
Omega, Curious & Wall angles  
Refer to attached Sheet (1/1)

Approved	<input type="checkbox"/>
Approved as noted	<input checked="" type="checkbox"/>
Revise and resubmit	<input type="checkbox"/>
Rejected	<input type="checkbox"/>
Sample required	<input type="checkbox"/>
Tests required	<input type="checkbox"/>
Additional information required	<input type="checkbox"/>
Manufacturer's guarantee required	<input type="checkbox"/>

Signature:

Shahin Farouk

Date:

26/07/2020

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.



dar





Badawy Group  
**BEECO**

010 6662 8713 - 010 0077 0610  
WWW.BADAWYBEECO.COM - CC@BADAWYBEECO.COM

## CO-38 Ceiling Accessories Fitting

Spring Channel (10mm)

Shadow Gap

Size: 214\*27\*1.3mm

Main Carrier (C 38)

T 0.5 - 1 mm / L 3 m

U Bead

T 0.5 - 1 mm / L 3 m

Well Angle 90°

T 0.5 - 1 mm / L 3 m

U Hang Thread bar

Corner bead

Curve Angle

Note  
Special Lengths,  
Thickness & Dimensions  
Can be produced

0.8mm  
as  
Special  
for Public  
areas

## Gypsum Boards

also  
to use

lengths as shop  
DD & Shop drawing  
Request

regular  
(12-15 mm)

Moisture Rated  
(12-15 mm)

(12-15 mm)

## Fitting & Finishing Accessories

Fiber Tape

Metal Tape

Wire Clip

Fixing Screws

Installation  
Screws