

Submittal for approval of materials

Date: 18/02/2020

Request no:

122 SOPHIA ARR -0451 Rev 00

Project no. & title: Project No.E16104-0400S/T-04 Ministerial Buildings On Plot 9B&10B

Employer: 	Engineer: 	Contractor: 
--	--	--

Beeco (C038)Gypsum Ceiling Suspension System

1 CD

No Sample

Area of applicat Ceiling According To Finishing Schedule(C14)

Drawing ref. : N/A

B.O.Q. ref. no.: 9260

Specification Ref 9260

Standards: N/A

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name Beeco

Address : 10 Ramadan City-industrial Zone A1-Plot 33/1

Local agent :

3. Delivery :

Country of origin Egypt

Availability

☒ Locally Manufactured

☐ Overseas

Delivery : Ex-works/ total duration [] []

Estimated time of arrival on site []

Program : Date material required on site []

Latest date for order []

I hereby certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver

Submitted by : Eng/ Ahmed ALDeeb

Signature: 

4. Engineer's Representative comments:

only for heavy duty system, final
party tests required for complete approval
* Mill Certificates confirming compliance
with project requirements is required.
Final approval subject to
approved samples, mock up

Signature: A.R.

Date: 22/2/2020

- ☐ Approved
- ☒ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☒ Sample required
- ☒ Tests required
- ☒ Additional information required
- ☒ Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization or any change to Contract Documents

See also submittal pack with the contract documents for further instructions